

www.agua-bona.es  
 Telf: 630 85 70 72  
 PASSEIG DE L'HAVANA 20  
 46890 AGULLENT  
 VALENCIA



NOMBRE: 17 2109 VM

<b>Valores, Ok.</b>			<b>Valores</b> muestra / AGUA <b>12-sep.-17</b> <b>RED</b>	<b>Valores</b> muestra / AGUA <b>12-sep.-17</b> <b>PISCINA</b>
0,4 - 3,00	mg / lit.	Cloro ( cl. )	0,80	0,50
entre 3 y 8	g / lit.	TDS	0,24	2,55
7,00 - 8,00		pH	8,01	6,95
15 - 25	Hº F	Dureza (cal)	20	32,4
60 - 180	ppm	Alcalinidad	120	40
menor a 75	mg/lit	Ac. Cianúrico	0	0
entre 3 y 5	g / lit.	sal / (Cl Na)	0,20	2,40