

www.agua-bona.es
 Telf: 658810741
 PASSEIG DE L'HAVANA 20
 46890 AGULLENT
 VALENCIA



NOMBRE: 15 3708 AS

Valores, Ok.			Valores muestra / AGUA 2-jul.-18	Valores muestra / AGUA 7-ago.-18
0,4 - 3,00	mg / lit.	Cloro (cl.)	0,2	0,9
entre 3 y 8	g / lit.	TDS	2,35	2,02
7,00 - 8,00		pH	7,54	7,55
15 - 25	Hº F	Dureza (cal)	39,6	41,4
60 - 180	ppm	Alcalinidad	40	40
menor a 75	mg/lit	Ac. Cianúrico	55	60
entre 3 y 5	g / lit.	sal / (Cl Na)	2,10	1,90